

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE

LISTING No. 7210-1218:103 Page 1 of 1

CATEGORY: Flame Detector

LISTEE: Detector Electronics, 6901 W. 110th Street, Minneapolis MN 55438
Contact: Jon Miller (612) 941-5665

DESIGN: Models 30-2025, 30-2025E, 30-2026, 30-2029, 30-2029E and 30-2056E. Models 30-2025 and 30-2029. Models with the suffix E are suitable for use in hazardous locations. Models 30-2025, 30-2026, 30-2029 and 30-2029E are intended for use in duct and other spot-type applications. Model 30-2056E is designed to detect radiation of flames of hydrocarbon liquids, solids and gases and will not detect hydrogen fires. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and FM label.

APPROVAL: Listed as IR flame detectors for use with separately listed compatible fire alarm control units. Authority having jurisdiction should be consulted prior to installation.

NOTE: Formerly 7210-0306:106



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 8, 2001**

*Listing Expires **June 30, 2002***

Authorized By: **BEN HO**, Supervising Deputy
Program Manager